



## Legislation Details (With Text)

<b>File #:</b>	18-482	<b>Version:</b>	1	<b>Name:</b>	PSA with Murraysmith I and I Program Support
<b>Type:</b>	Contract	<b>Status:</b>		<b>Status:</b>	Consent Agenda
<b>File created:</b>	10/8/2018	<b>In control:</b>		<b>In control:</b>	City Commission
<b>On agenda:</b>	10/17/2018	<b>Final action:</b>		<b>Final action:</b>	
<b>Title:</b>	Personal Services Agreement with Murraysmith, Inc. for Engineering Services for the City's Sewer Infiltration and Inflow (I & I) Program Support				
<b>Sponsors:</b>	John Lewis				
<b>Indexes:</b>	Goal 2: Address Critical Facility Needs., Goal 3: Enhance the Livability of the Community., Goal 4: Seek Opportunities to Maintain Communications with Citizens and Facilitate Citizen Participation.				
<b>Code sections:</b>					
<b>Attachments:</b>	1. Staff Report, 2. Personal Services Agreement, 3. Exhibit A - Scope of Work, 4. Exhibit B - Standard Conditions, 5. Smoke Testing Map				

Date	Ver.	Action By	Action	Result
------	------	-----------	--------	--------

Personal Services Agreement with Murraysmith, Inc. for Engineering Services for the City's Sewer Infiltration and Inflow (I & I) Program Support

### RECOMMENDED ACTION (Motion):

Authorize the City Manager to execute the Personal Services Agreement (PSA) in the amount of \$139,248.00 with Murraysmith, Inc. (Murraysmith) to provide engineering services for the Inflow and Infiltration (I/I) characterization and reduction program.

### BACKGROUND:

The City conducts an ongoing program to improve the sewer collection system by reducing unwanted surface water inflow and groundwater infiltration. Inflow occurs when surface water drainage is improperly piped into the sewer system. Infiltration occurs when cracks or other defects in the sewer lines allow groundwater to enter. Unwanted I & I that gets into the sewer system increases the risk of sewage overflows and unnecessarily increases the volume of wastewater treated at the treatment plant, ultimately increasing ratepayer costs.

Smoke testing of select areas was completed in September 2018 following flow monitoring of the sewers carried out in 2012 and early 2016. Based on flow monitoring and smoke testing results, the City has identified priority focus areas to target solutions to storm sewer / sanitary sewer cross connections, illegally connected private gutter downspouts, and to further investigate pipe conditions for infiltration.

The attached scope is for engineering assistance from Murraysmith for further interpretation of testing results, assistance with planning further pipe condition assessment efforts, and development of short, medium and long-term correction CIP (Capital Improvement Project) programs. Tasks also include developing policy and construction standards for rehabilitation or replacement of private laterals and disconnection of inflow sources such as gutter downspouts and foundation drains.

The recommended authorization is for Tasks 1-3 in the attached scope document (Exhibit A). Authorization of Task 4 is not included in this decision however the scope was drafted to acknowledge the need for this work and to provide a preview of the scope and potential costs for design and construction services for short and middle-term CIP projects. A more detailed Task 4 will likely come forward in the form of an amendment or separate PSA.

Over the next five years, the City expects this work combined with the follow up construction will result in measurable strides in reducing sewer inflow and infiltration.

We request the Commission support the City's I & I reduction efforts and authorize the City Manager to execute this PSA in the amount of \$139,248.

**BUDGET IMPACT:**

Amount: \$139,248.00  
FY(s): 2018-19  
Funding Source: Sewer Fund